

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.0324	x	311	x	8.34	=	84
February	0.0329	x	325	x	8.34	=	89
March	0.0285	x	349	x	8.34	=	83
April	0.0317	x	251	x	8.34	=	66
May	0.0336	x	297	x	8.34	=	83
June	0.0367	x	252	x	8.34	=	77
July	0.0310	x	269	x	8.34	=	70
August	0.0314	x	239	x	8.34	=	63
September	0.0406	x	294	x	8.34	=	100
October	0.0628	x	139	x	8.34	=	73
November	0.0393	x	240	x	8.34	=	79
December	0.0520	x	280	x	8.34	=	122

2. Maximum Monthly Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.105	x	90	=	0.0945
		x	100	=	.105
Design (C)BOD, lbs/day	135	x	90	=	121.5
		x	100	=	135

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	1	0
Points per each		2	1	3	2
Exceedances		0	0	1	0
Points		0	0	3	0
Total Number of Points					3

3

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

- Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

- Yes
 No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

- Yes
 No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

- | Septic Tanks | Holding Tanks | Grease Traps |
|-------------------------------------|-------------------------------------|-------------------------------------|
| <input type="radio"/> Yes | <input type="radio"/> Yes | <input type="radio"/> Yes |
| <input checked="" type="radio"/> No | <input checked="" type="radio"/> No | <input checked="" type="radio"/> No |

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks
 Yes gallons

No

Holding Tanks
 Yes gallons

No

Grease Traps
 Yes gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

- Yes
 No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 2018

Resolution or Owner's Statement

Name of Governing
Body or Owner:

Village of Montfort

Date of Resolution or
Action Taken:

Resolution Number:

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Phosphorus: Grade = D

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.72

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 2018

Yes

No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

--

Total Points Generated	3
Score (100 - Total Points Generated)	97
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	8	1	0	0
February	30	27	6	1	0	0
March	30	27	5	1	0	0
April	30	27	2	1	0	0
May	30	27	0	1	0	0
June	30	27	0	1	0	0
July	30	27	3	1	0	0
August	30	27	2	1	0	0
September	30	27	4	1	0	0
October	30	27	3	1	0	0
November	30	27	3	1	0	0
December	30	27	5	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)
2018-11-28

No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

If Yes, please explain:

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?
 Yes
 No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?
 Yes
 No
 N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	3	1	0	0
February	30	27	2	1	0	0
March	30	27	2	1	0	0
April	30	27	1	1	0	0
May	30	27	0	1	0	0
June	30	27	0	1	0	0
July	30	27	1	1	0	0
August	30	27	2	1	0	0
September	30	27	0	1	0	0
October	30	27	0	1	0	0
November	30	27	3	1	0	0
December	30	27	2	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:	7	3	
Exceedances	0	0	
Points	0	0	
Total Number of Points		0	

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	5.8	5.362	1	0
February	5.8	6.396	1	1
March	5.8	6.510	1	1
April	5.8	5.245	1	0
May	5.8	4.882	1	0
June	5.8	5.021	1	0
July	5.8	5.787	1	0
August	5.8	6.707	1	1
September	5.8	5.658	1	0
October	5.8	2.599	1	0
November	5.8	4.053	1	0
December	5.8	3.511	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				3
Total Number of Points				30

30

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

We have done non point trading.

Total Points Generated	30
Score (100 - Total Points Generated)	70
Section Grade	D

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 2018

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
 Publicly Distributed Exceptional Quality Biosolids
 Hauled to another permitted facility
 Landfilled
 Incinerated
 Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 003 - SLUDGE

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75						.081								0	0
Cadmium		39	85						<.083								0	0
Copper		1500	4300						19								0	0
Lead		300	840						64.5								0	0
Mercury		17	57						.01								0	0
Molybdenum	60		75						.283							0		0
Nickel	336		420						1.28							0		0
Selenium	80		100						.157							0		0
Zinc		2800	7500						51.2								0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)
- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified? <input type="text"/>	0
6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site? ● <input checked="" type="radio"/> >= 180 days (0 Points) ○ 150 - 179 days (10 Points) ○ 120 - 149 days (20 Points) ○ 90 - 119 days (30 Points) ○ < 90 days (40 Points) ○ N/A (0 Points) 6.2 If you checked N/A above, explain why. <input type="text"/>	0
7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management: <input type="text" value="None"/>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none">● Yes (Continue with question 2) <input type="checkbox"/><input type="checkbox"/>○ No (40 points) <input type="checkbox"/><input type="checkbox"/> <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none">● Yes○ No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none">● Yes<ul style="list-style-type: none">● Paper file system○ Computer system○ Both paper and computer system○ No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?</p> <ul style="list-style-type: none">● Yes○ No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none">● Excellent○ Very good○ Good○ Fair○ Poor <p>Describe your rating:</p>	

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

We have B&M tech services to calibrate and test equipment & when ever we need service. We also preform regular maintenance & exercised as needed. We did plant up grade so L.W. Allen set everything up in 2018.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 2018

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (20 points) <p>Name: <input style="width: 300px;" type="text" value="TODD R GRIFFITHS"/></p> <p>Certification No: <input style="width: 150px;" type="text" value="36340"/></p>	0																																																																																								
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?</p> <table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th rowspan="2">Sub Class</th> <th rowspan="2">SubClass Description</th> <th colspan="2">WWTP</th> <th colspan="2">OIC</th> </tr> <tr> <th>Basic</th> <th>OIT</th> <th>Basic</th> <th>Advanced</th> </tr> </thead> <tbody> <tr><td>A1</td><td>Suspended Growth Processes</td><td></td><td></td><td></td><td></td></tr> <tr><td>A2</td><td>Attached Growth Processes</td><td></td><td></td><td></td><td></td></tr> <tr><td>A3</td><td>Recirculating Media Filters</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>A4</td><td>Ponds, Lagoons and Natural</td><td></td><td></td><td></td><td></td></tr> <tr><td>A5</td><td>Anaerobic Treatment Of Liquid</td><td></td><td></td><td></td><td></td></tr> <tr><td>B</td><td>Solids Separation</td><td></td><td></td><td></td><td></td></tr> <tr><td>C</td><td>Biological Solids/Sludges</td><td></td><td></td><td></td><td></td></tr> <tr><td>P</td><td>Total Phosphorus</td><td></td><td>X</td><td></td><td></td></tr> <tr><td>N</td><td>Total Nitrogen</td><td></td><td></td><td></td><td></td></tr> <tr><td>D</td><td>Disinfection</td><td>X</td><td></td><td>X</td><td></td></tr> <tr><td>L</td><td>Laboratory</td><td></td><td></td><td></td><td></td></tr> <tr><td>U</td><td>Unique Treatment Systems</td><td></td><td></td><td></td><td></td></tr> <tr><td>SS</td><td>Sanitary Sewage Collection</td><td>X</td><td>NA</td><td>NA</td><td>NA</td></tr> </tbody> </table> <p>2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS, N and A5 not required in 2018; subclass SS is basic level only.)</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (20 points) 	Sub Class	SubClass Description	WWTP		OIC		Basic	OIT	Basic	Advanced	A1	Suspended Growth Processes					A2	Attached Growth Processes					A3	Recirculating Media Filters	X		X		A4	Ponds, Lagoons and Natural					A5	Anaerobic Treatment Of Liquid					B	Solids Separation					C	Biological Solids/Sludges					P	Total Phosphorus		X			N	Total Nitrogen					D	Disinfection	X		X		L	Laboratory					U	Unique Treatment Systems					SS	Sanitary Sewage Collection	X	NA	NA	NA	0
Sub Class			SubClass Description	WWTP		OIC																																																																																			
	Basic	OIT		Basic	Advanced																																																																																				
A1	Suspended Growth Processes																																																																																								
A2	Attached Growth Processes																																																																																								
A3	Recirculating Media Filters	X		X																																																																																					
A4	Ponds, Lagoons and Natural																																																																																								
A5	Anaerobic Treatment Of Liquid																																																																																								
B	Solids Separation																																																																																								
C	Biological Solids/Sludges																																																																																								
P	Total Phosphorus		X																																																																																						
N	Total Nitrogen																																																																																								
D	Disinfection	X		X																																																																																					
L	Laboratory																																																																																								
U	Unique Treatment Systems																																																																																								
SS	Sanitary Sewage Collection	X	NA	NA	NA																																																																																				
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> One or more additional certified operators on staff <input type="checkbox"/> An arrangement with another certified operator <input checked="" type="checkbox"/> An arrangement with another community with a certified operator <input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year <input type="checkbox"/> A consultant to serve as your certified operator <input type="checkbox"/> None of the above (20 points) <p>If "None of the above" is selected, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0																																																																																								
<p>4. Continuing Education Credits</p>																																																																																									

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 2018

4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates? OIT and Basic Certification: ● Averaging 6 or more CECs per year. ○ Averaging less than 6 CECs per year. Advanced Certification: ○ Averaging 8 or more CECs per year. ○ Averaging less than 8 CECs per year.	
--	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 150px;" type="text" value="Shelley Kazda"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="608-943-6917"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 300px;" type="text" value="clerk@montfortvillage.com"/></p>																
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <p>● Yes (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ No (40 points)</p> <p>If No, please explain: <input style="width: 800px; height: 20px;" type="text"/></p> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised? Year: <input style="width: 100px;" type="text" value="2018"/></p> <p>● 0-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A (private facility)</p> <p>2.3 Did you have a special account (e.g., CWFP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <p>● Yes (0 points)</p> <p>○ No (40 points)</p>	0															
<p>REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]</p>																
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised? Year: <input style="width: 100px;" type="text" value="2018"/></p> <p>● 1-2 years ago (0 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ 3 or more years ago (20 points) <input type="checkbox"/><input type="checkbox"/></p> <p>○ N/A</p> <p>If N/A, please explain: <input style="width: 800px; height: 20px;" type="text"/></p>																
<p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%; text-align: center;">\$</td> <td style="width: 35%; text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="71,310.60"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: center;">\$</td> <td style="text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td style="text-align: center;">\$</td> <td style="text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="71,310.60"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: center;">\$</td> <td style="text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="1,353.93"/></td> </tr> <tr> <td></td> <td style="text-align: center;">+</td> <td style="text-align: right;"><input style="width: 100%; border: 1px solid black;" type="text" value="1,353.93"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="71,310.60"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="71,310.60"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="1,353.93"/>		+	<input style="width: 100%; border: 1px solid black;" type="text" value="1,353.93"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="71,310.60"/>														
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="0.00"/>														
3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="71,310.60"/>														
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	\$	<input style="width: 100%; border: 1px solid black;" type="text" value="1,353.93"/>														
	+	<input style="width: 100%; border: 1px solid black;" type="text" value="1,353.93"/>														

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 2018

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)

- \$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year

\$ 72,664.53

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund?

\$ 72,664.53

0

Please note: If you had a CWFPP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	rehabbing existing plant and looking at in pack of phosphorus removal	1000000	2018
2	Replacement of 1050 ft. Of 8" sanitary sewer. replace 7 manholes.	95400	2014
3	Replacement of 1450 ft of 8" sanitary sewer and 9 manholes.	109325	2015
4	Replacing and updating collection system on North St. project.	110000	2019

5. Financial Management General Comments

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	183	
February	264	
March	132	
April	140	
May	149	
June	204	
July	253	
August	215	
September	213	
October	209	
November	241	
December	208	
Total	2,411	0
Average	201	0

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

● No

○ Yes

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	2,767	1.00	2,767	2.60	1,064	
February	4,394	0.92	4,776	2.49	1,765	
March	3,535	0.88	4,017	2.57	1,375	
April	3,804	0.95	4,004	1.98	1,921	
May	3,736	1.04	3,592	2.57	1,454	
June	3,856	1.10	3,505	2.31	1,669	
July	3,900	0.96	4,063	2.17	1,797	
August	3,181	0.97	3,279	1.95	1,631	
September	2,530	1.22	2,074	3.00	843	
October	1,736	1.95	890	2.26	768	
November	1,019	1.18	864	2.37	430	
December	1,439	1.61	894	3.78	381	
Total	35,897	13.78		30.05		0
Average	2,991	1.15	2,894	2.50	1,258	0

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification
- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

We pump to a recirculating sand filter.

7.2.2 Comments:

U.V. disinfection is May-Oct.

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

We have up graded U.V. and replaced pumps in 2018/2019.

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

Flared Off

Building Heat

Process Heat

Generate Electricity

Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 2018

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

- Yes
- No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

- Yes
- No (30 points)
- N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

- Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

To televise & clean 10% of sewer mains, inspect 25% of s.s.m.holes/year, upgrade or replace 5% of s.s.m.holes/year, replace or rehabilitate 5% of sewer mains, laterals/year, update maps, cont. with GIS program, cont. with a prioritized preventative maintenance schedule with assigned work hours to the collection system issues.

Did you accomplish them?

- Yes
- No

If No, explain:

We didn't replace any sewer main (we plan to do a project in 2019), we only upgraded two M.H.s. no I/I inspections were completed.

- Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

- Organizational structure and positions (eg. organizational chart and position descriptions)
- Internal and external lines of communication responsibilities
- Person(s) responsible for reporting overflow events to the department and the public

- Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

sewer use ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY)

2004-04-09

Does your sewer use ordinance or other legally binding document address the following:

- Private property inflow and infiltration
- New sewer and building sewer design, construction, installation, testing and inspection
- Rehabilitated sewer and lift station installation, testing and inspection
- Sewage flows satellite system and large private users are monitored and controlled, as necessary
- Fat, oil and grease control
- Enforcement procedures for sewer use non-compliance

- Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:
5/8/2019 **2018**

- Equipment and replacement part inventories
- Up-to-date sewer system map
- A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
- A description of routine operation and maintenance activities (see question 2 below)
- Capacity assessment program
- Basement back assessment and correction
- Regular O&M training

Design and Performance Provisions [NR 210.23 (4) (e)]

What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?

- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
- Construction, Inspection, and Testing
- Others:

Overflow Emergency Response Plan [NR 210.23 (4) (f)]

Does your emergency response capability include:

- Responsible personnel communication procedures
- Response order, timing and clean-up
- Public notification protocols
- Training
- Emergency operation protocols and implementation procedures

Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]

Special Studies Last Year (check only those that apply):

- Infiltration/Inflow (I/I) Analysis
- Sewer System Evaluation Survey (SSES)
- Sewer Evaluation and Capacity Management Plan (SECAP)
- Lift Station Evaluation Report
- Others:

0

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input style="width: 60px; height: 20px;" type="text" value="15"/>	% of system/year
Root removal	<input style="width: 60px; height: 20px;" type="text" value="0"/>	% of system/year
Flow monitoring	<input style="width: 60px; height: 20px;" type="text" value="0"/>	% of system/year
Smoke testing	<input style="width: 60px; height: 20px;" type="text" value="0"/>	% of system/year
Sewer line televising	<input style="width: 60px; height: 20px;" type="text" value="15"/>	% of system/year
Manhole inspections	<input style="width: 60px; height: 20px;" type="text" value="25"/>	% of system/year
Lift station O&M	<input style="width: 60px; height: 20px;" type="text" value="2"/>	# per L.S./year
Manhole rehabilitation	<input style="width: 60px; height: 20px;" type="text" value="1"/>	% of manholes rehabbed
Mainline rehabilitation	<input style="width: 60px; height: 20px;" type="text" value="0"/>	% of sewer lines rehabbed

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

Private sewer inspections % of system/year
 Private sewer I/I removal % of private services
 River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

Total actual amount of precipitation last year in inches
 Annual average precipitation (for your location)
 Miles of sanitary sewer
 Number of lift stations
 Number of lift station failures
 Number of sewer pipe failures
 Number of basement backup occurrences
 Number of complaints
 Average daily flow in MGD (if available)
 Peak monthly flow in MGD (if available)
 Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

Lift station failures (failures/year)
 Sewer pipe failures (pipe failures/sewer mile/yr)
 Sanitary sewer overflows (number/sewer mile/yr)
 Basement backups (number/sewer mile)
 Complaints (number/sewer mile)
 Peaking factor ratio (Peak Monthly:Annual Daily Avg)
 Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume (MG)
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

no issue

5.4 What is being done to address infiltration/inflow in your collection system?

no issue

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Montfort Wastewater Treatment Facility

Last Updated: Reporting For:

5/8/2019

2018

Grading Summary

WPDES No: 0024821

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Phosphorus	D	1	3	3
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			32	119
GRADE POINT AVERAGE (GPA) = 3.72				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)